



कार्यालय अधिशासी अभियन्ता,  
खण्ड कार्यालय, उत्तर प्रदेश जल निगम (ग्रामीण), बदायूँ।  
मा0 कांशीराम आवसीय कालोनी के पीछे, ग्राम- खेड़ा बुजुर्ग, बदायूँ-243601

E-mail -eejalnigambudaun@gmail.com

पत्रांक १२१ / M-LL / ३०

दिनांक 24/03/2026

सेवा में,

Blooming Dale School,  
Shyam Nagar, Bareilly- Mathura Road Budaun,  
Distt- Budaun (UP)-243601

विषय :- प्रेषित किये गये जल नमूनें की जाँच के सम्बन्ध में।

महोदय,

उपरोक्त विषयक आपके कार्यालय पत्रांक शून्य/2025-26जांच/दिनांक-19-03-2026 के द्वारा 01 नग जल नमूना जनपदीय जल परीक्षण प्रयोगशाला, उ0 प्र0 जल निगम (ग्रामीण), बदायूँ पर Chemical & Bacteriological जाँच कराने हेतु उपलब्ध कराया गया है। जल नमूनें की Chemical & Bacteriological जाँच कर ली गई है। जाँच रिपोर्ट निर्धारित प्रारूप पर संलग्न कर प्रेषित है।

संलग्नक- जाँच रिपोर्ट।

भवदीय

*[Signature]*  
अधिशासी अभियन्ता

पृ0सं0 एवं दिनांक- उपरोक्तानुसार  
प्रतिलिपि:-

सहायक अभियन्ता/जू0इं0 प्रयोगशाला, बदायूँ सूचनार्थ एवं आवश्यक कार्यवाही हेतु प्रेषित।

अधिशासी अभियन्ता



**Water Analysis Report**  
**District Level Water Analysis Laboratory**  
**U.P. Jal Nigam (Rural), Budaun**

Report No.	57	Date	24-03-2026	Page No	01
------------	----	------	------------	---------	----

**Customer Details**

Name & Address	Office of Executive Engineer, Khand Karyalay, U.P Jal-Nigam (Rural), Behind Manya. Kashiram Awasiya Colony, Kheda bujurg, District-Budaun.
Reference Letter No. & Date	620/011-Prayogshala/23 ,Dated 09/05/2023

**Basic Details of the Sample**

District	Budaun	Block	Budaun
Gram Panchayat	-	Village	-
Habitation	Blooming Dale School Budaun	Location	Shayam Nagar, Bareilly – Mathura Road, Budaun(UP)
Water Source	Hand Pump	Sample No.	55
Quantity of the Sample	1Ltr	Date of Sample Collection	19-03-2026
Receiving Date	19-03-2026	Sample Collector	Vipin Kumar
Sample Depositor	Vipin Kumar		
Analysis Start Date	20-03-2026	Analysis Completion Date	22-03-2026

**Environmental Condition**

Temperature	25±3°C	Humidity	50±15 %
-------------	--------	----------	---------

**TEST REPORT**

S.No	Analysed Parameter	Observed Value	Specified Values as per BIS 10500:2012		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	Odour	Agreeable	Agreeable	Agreeable	IS:3025(Part-5):2018
2	Taste	Agreeable	Agreeable	Agreeable	IS:3025(Part-8):2023
3	pH @25°C	7.30	6.5-8.5	6.5-8.5	IS 3025(Part 11):2022
4	Turbidity(NTU)	0.35	1	5	IS 3025 (Part 10):2017
5	Total Dissolved Solid(mg/L)	230	500	2000	IS 3025 (Part 16):2019
6	Chloride(mg/L)	55	250	1000	IS 3025(Part 32):1988
7	Total Alkalinity(mg/L)	102	200	600	IS 3025 (Part 23):2023
8	Total Hardness(mg/L)	60	300	600	IS 3025 (Part 21):2009
9	Calcium(mg/L)	10.20	75	200	IS 3025 (Part 40):2023
10	Magnesium	9.35	30	100	IS 3025 (Part 46):2023

Note	1. This certificate refers only to the particular sample(s) submitted for testing.
	2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from the Head of the Laboratory.
	3. The Test results reported in this certificate are valid at the time of and under the stated conditions of Measurements.
	4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of Tests report unless Otherwise Specified.
	5. Parameters above Permissible Limit This are Written in Bold.

Revised By

(Ayushi Gangwar)  
Authorised Signatory



# Water Analysis Report

DISTRICT LEVEL WATER ANALYSIS LABORATORY, U.P JAL NIGAM (BUDAUN)

## BACTERIOLOGICAL SAMPLE TEST REPORT

Report No.	57	Date	24-03-2026	Page No.	01
------------	----	------	------------	----------	----

### Customer Details

Name & Address	Office of Executive Engineer, Khand Karyalay, U.P Jal Nigam (Rural), Behind Manya. Kashiram Awasiya Colony, Kheda bujurg. Dudaun.
Ref Letter No.&Date	620/011-Prayogshala/23 Dated 09/5/2023.

### Basic details of sample

District	Budaun	Block	Budaun
Gram panchayat	-	Village	-
Habitation	Blooming Dale School Budaun	Location	Shayam Nagar, Bareilly – Mathura Road, Budaun(UP)
Water Source	Hand pump	Sample No.	57
Quantity of Sample	1/L	Date of Sample Collection Date	19-03-2026
Receiving Date	19-03-2026	Sample Collector	Vipin kumar
Analysis Start Date	20-03-2026	Analysis Completion Date	22-03-2026

### Environmental Condition

Temperature	25±3°C	Humidity	50±15%
-------------	--------	----------	--------

### Technical Data of Analysis

Sr.No.	Units	Observed Value	Specified Values as per IS 10500:2021		Ref. Method of Analysis	
			Acceptable Limit	Permissible Limit		
1	2	3	4	5	6	7
1	Total coliform	CFU	0.0	No Relaxation	0.0 CFU/100mL	APHA23 <sup>rd</sup> Edition:2017
2	E.Coli	CFU	0.0	No Relaxation	0.0 CFU/100mL	APHA23 <sup>rd</sup> Edition:2017

### Note:-

- 1.This Certificate refers only to the particular sample(s) submitted for testing.
2. This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of laboratory.
3. The Test result reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 15 days (in case of non perishable items only) from the date of issue of test reports unless otherwise specified.

(SWATI PRIVADARSHI)  
Result approved by  
Laboratory Microbiologist

